



संशोधनेन संवृद्धिः

MINUTES OF PRE-BID MEETING FOR TENDER WORK 315 KVA TRANSFORMER WORK at NAGPUR FARM

Date & Time: .21.09.2024 at 14.00

Venue: Vasantdada Sugar Institute Office.

The representative of M/S Sonhira electric company was only present. The point raised by the contractor & clarification furnished is as under.

- 1) What is size and quantity of control cable

Clarification: 2.5 sqmm 19 core copper armoured cable is to be used and length of cable is Approximately 20 mtrs.

- 2) Which make of jointing kit to be used?

Clarification: Raychem, 3M, MSEDCL Approved make is to be used

- 3) In whose scope of Lisoning cost & drawing?

Clarification: These works are in the scope of contractor

- 4) In whose scope of Transformer foundation plinth & earthling?

Clarification: These works are in the scope of VSI

Considering the Clarification given all prospective bidders are advised to submit unconditional offers.